IMPACT OF PLUG IN ELECTRIC VEHICLE BATTERY CHARGING ON A
DISTRIBUTION SYSTEM

By

Sharmila Kumari Bunga

Approved:

Ahmed H. Eltom
Professor of Electrical Engineering
(Thesis Advisor)

Abdul R. Ofoli
Assistant Professor of Electrical Engineering
(Committee member)

Nurhidajat Sisworahardjo
Assistant Professor of Electrical Engineering
(Committee member)

William H. Sutton
Dean, the College of Engineering and
Computer Sciences

A. Jerald Ainsworth
Dean, the Graduate School

IMPACT OF PLUG IN ELECTRIC VEHICLE BATTERY CHARGING ON A
DISTRIBUTION SYSTEM

By

Sharmila Kumari Bunga

A Thesis Submitted to the Faculty of the University of
Tennessee at Chattanooga in Partial Fulfillment
of the Requirements of the Degree of
Master's of Science in Engineering

The University of Tennessee at Chattanooga
Chattanooga, Tennessee

May 2013

ABSTRACT

Plug-in Electric Vehicles (PEV) battery chargers are mostly connected to the low-voltage grid for charging, hence their increased penetration coupled with uncoordinated charging could impact the distribution system in terms of voltage unbalance and transformer overloading. Although PEV battery charging is increasing, impact on the distribution system is not fully understood.

This study focuses on voltage unbalance caused by uneven distribution of PEV penetration among the phases. Using real data provided by utility, a distribution system has been modeled and tested using MATLAB-SIMULINK. PEV penetration level at 10-80% is studied, voltage unbalance is calculated and transformer overloading is analyzed. In the simulations conducted without PEV penetration, the real data at intellirupters of the system were close to simulated system voltages and currents. As PEV adoption is expected to increase, the impact on the distribution system will increase. Coordinated or smart charging of PEVs will be essential for consumers and utilities.

DEDICATION

I dedicate this work to my parents and in-laws, for their love, encouragement, and support.

ACKNOWLEDGEMENTS

The first person I would like to express my heartfelt gratitude is Dr. Ahmed Eltom whose support and supervision has been unlimited throughout this thesis and my masters. I am indebted to the opportunity he has provided me with. He molded me in the right direction and taught me to be positive always.

I would like to thank the other members of my thesis committee, namely, Dr. Abdul Ofoli and Dr. Nurhidajat Sisworahardjo for their invaluable aid and direction in this thesis.

I would also like to thank Dr. Stephen D. Craven for his guidance and supervision provided throughout the intricacies of the master's program and thesis process.

I would also like to thank Bob Hay of EPB (Electric Power Board) for guiding me throughout the thesis and helping me by providing necessary data & valuable advice.

I reserve my special thanks to my husband Raj; I couldn't have accomplished all this without his encouragement, love, and most importantly his constructive criticism. I deeply appreciate and acknowledge all the love and support I received from my family and their belief in me.

I would like to thank my fellow graduate students, for their friendships and support. The last two years have been quite an experience and you have all made it a memorable time of my life. Also, I am very grateful to my close family friends Sujatha and Yugandhar for their encouragement and for being a constant source of support both morally and emotionally which always made me feel at home.

TABLE OF CONTENTS

ABSTRACT	iii
DEDICATION	iv
ACKNOWLEDGEMENTS	v
LIST OF TABLES	viii
LIST OF FIGURES	x
LIST OF ABBREVIATIONS	xi
CHAPTER	
1. INTRODUCTION	1
1.1 Background	1
1.2 PEVs Market and Government Policy	2
1.3 Statement of the Problem	4
1.4 Thesis Organization	5
2. LITERATURE REVIEW	6
2.1 Types of Plug-in Electric Vehicles	6
2.1.1 Battery Electric Vehicles	6
2.1.2 Plug-in Hybrid Electric Vehicles	7
2.1.3 Extended-Range Electric Vehicles	7
2.2 PEV Charging Characteristics	8
2.2.1 AC Level 1 Charger	8
2.2.2 AC Level 2 Charger	9
2.2.3 AC Level 3 Charger	10
2.3 Impact of PEVs on the electric grid	11
2.3.1 Impact on Generation	11
2.3.2 Impact on Transmission	12
2.3.3 Impact on Distribution	12
2.4 Implications of voltage unbalance	13

3. MODELING OF A DISTRIBUTION SYSTEM USING MATLAB - SIMULINK	14
3.1 Matlab - Simulink Software	14
3.2 Modeled Distribution System	14
3.3 Overhead lines and underground cables	18
3.4 Service Transformers	21
3.5 Distribution system load	23
3.6 Residential Power Demand	25
3.7 Level 2 battery charger model using MATLAB-SIMULINK	25
4. DISTRIBUTION SYSTEM LOAD DATA ANALYSIS	27
4.1 Introduction	27
4.2 Reactive Power Calculations	29
4.3 Active to Reactive Power Ratio at Peak and Off-Peak	30
5. CASE STUDY AND SIMULATION RESULTS	35
5.1 Simulink model testing without PEV penetration	36
5.1.1 Voltages and currents at peak demand	36
5.1.2 Voltages and currents at off-peak demand	39
5.2 Simulink model testing with PEV penetration	41
5.2.1 Studied system with 10% PEV penetration	42
5.2.2 Studied system with 30% PEV penetration	45
5.2.3 Studied system with 50% PEV penetration	47
5.2.4 Studied system with 60% PEV penetration	49
5.2.5 Studied system with 70% PEV penetration	52
5.2.6 Studied system with 80% PEV penetration	55
5.3 Impact of PEV Penetration on Simulated System	57
5.4 Impact of high PEV Penetration on one phase	59
6. CONCLUSION	60
REFERENCES	61
APPENDIX	
A. DISTRIBUTION SYSTEM FOR VOLTAGE STUDY	65
B. INTELLIRUPTERS DATA	68
VITA	70

LIST OF TABLES

2.1 PEV charging characteristics for various levels	10
3.1 Impedances of Overhead Lines	20
3.2 Resistances, Inductances and Capacitances of OH lines and UG cables	20
3.3 Service transformer Impedances by rating	22
3.4 Nominal current ratings of single-phase transformers	23
4.1 Peak and Off-Peak Active and Reactive Powers for CB1 and CB2	30
4.2 Active to Reactive Power Ratio of the system	30
4.3 Real and Reactive power demands for all service transformers	32
5.1 Measured and actual phase voltages and currents at CB1 at peak demand	37
5.2 Measured and actual phase voltages and currents at CB2 at peak demand	38
5.3 Measured and actual phase voltages and currents at CB1 at off-peak demand	40
5.4 Measured and actual phase voltages and currents at CB2 at off-peak demand	41
5.5 Phase voltages at peak and off-peak demand for 10% penetration of PEVs	44
5.6 Phase voltages at peak and off-peak demand for 30% penetration of PEVs	46
5.7 Phase voltages at peak and off-peak demand for 50% penetration of PEVs	48
5.8 Phase voltages at peak and off-peak demand for 60% penetration of PEVs	50
5.9 Rated and Measured Currents for Phase-B Transformers in the simulated system	52
5.10 Phase voltages at peak and off-peak demand for 70% penetration of PEVs	54
5.11 Phase voltages at peak and off-peak demand for 80% penetration of PEVs	56

LIST OF FIGURES

1.1 Projected New Vehicle Market Share Categories	3
2.1 Level 2 charging station	9
2.2 AC/DC Combo Coupler and Receptacle based on SAE 1772 TM	11
3.1 One line diagram of the studied distribution system	15
3.2 Two sections of one line diagram of the studied system	15
3.3 MATLAB-SIMULINK model of studied system	16
3.4 Simplified one line diagram of distribution system layout	17
3.5 Simulink distribution system layout of subsystem section 1	17
3.6 Simulink distribution system layout of subsystem section 2	18
3.7 Three phase pie section line block	19
3.8 Connection diagram of a single phase transformer	21
3.9 Sample SimPowerSystems block for the single-phase transformer	22
3.10 Total Active Power for 4 days	24
3.11 Total Reactive Power for 4 days	24
3.12 Battery charger model using MATLAB-SIMULINK	25
4.1 Two sections of one line diagram of studied system	27
4.2 True Active Power at CB1	28
4.3 True Reactive Power at CB1	29
4.4 Total real power of each service transformer at peak and off-peak demand	33

4.5 Total reactive power of each service transformer at peak and off-peak demand	34
5.1 Simplified diagram of the modeled distribution system	35
5.2 Measured three-phase voltages at CB1 of the system at peak demand	36
5.3 Measured three-phase currents at CB1 of the system at peak demand	37
5.4 Measured three-phase voltages at CB2 of the system at peak demand	38
5.5 Measured three-phase currents at CB2 of the system at peak demand	38
5.6 Measured three-phase voltages at CB1 of the system at off-peak demand	39
5.7 Measured three-phase currents at CB1 of the system at off- peak demand	39
5.8 Measured three-phase voltages at CB2 of the system at off- peak demand	40
5.9 Measured three-phase currents at CB2 of the system at off- peak demand	41
5.10 Distribution system model with 10 % of PEV Penetration	43
5.11 Distribution system model with 30 % of PEV Penetration	45
5.12 Distribution system model with 50 % of PEV Penetration	47
5.13 Distribution system model with 60 % of PEV Penetration	50
5.14 Distribution system model with 70% of PEV Penetration	53
5.15 Distribution system model with 80 % of PEV Penetration	55
5.16 Maximum Voltage Deviation with level of PEV Penetration	58
5.17 %Voltage Unbalance with level of PEV Penetration	59

LIST OF ABBREVIATIONS

AC, Alternating Current

AER, All Electric Range

AL, Aluminum

ALXLP, Aluminum Cross Linked Polyethylene

BEV, Battery Powered Electric Vehicle

CB, Circuit Breaker

CV, Conventional Vehicle

DC, Direct Current

EREV, Extended Range Electric Vehicle

EV, Electric Vehicle

HEV, Hybrid Electric Vehicle

IEEE, Institute of Electrical and Electronics Engineers

KV, Kilo volts

KVA, Kilo Volt-Ampere

KVAR, Kilo volt-ampere reactive

KW, Kilo watt

KWH, Kilo watt hour

LVUR, Line Voltage Unbalance Rate

MVAR, Mega volt-ampere reactive

MW, Mega watt

NEMA, National Electrical Manufacturer Association

OH, Overhead

PEV, Plug-in Electric Vehicle

PHEV, Plug-in Hybrid Electric Vehicle

PVUR, Phase Voltage Unbalance Rate

RMS, Root mean square

SAE, Society of Automotive Engineers

SOC, State of Charge

UG, Underground

VU, Voltage Unbalance

ZEV, Zero Emission Vehicle

CHAPTER 1

INTRODUCTION

1.1 Background

The traditional dependence on fossil fuels has undoubtedly made the transportation a primary contributor to the greenhouse emissions. As passenger vehicle is accounting for more than half of the total electrification of transportation energy requirement, it is the major consumer of the energy [1]. However the technological strides that are made and being made in the field of plug-in electric vehicles (PEVs) are becoming central to combating greenhouse gas emissions, namely the Battery Powered Electric Vehicle (BEV) and Plug-in Hybrid Electric Vehicle (PHEV).

The promising direction of PEVs for transportation is two-fold; PEVs can reduce the reliance on fossil fuels hence limiting the greenhouse gas emissions, as well, electricity as an energy source for passenger cars is less expensive per mile than fossil fuels [2]. While Hybrid Electric Vehicles (HEV) are earlier cousins of EVs, in comparison, PHEVs and BEVs have more onboard energy storage than HEVs, and also give owners the ability to charge the vehicle battery from a stationary electrical source for example, an outlet in the garage or a charging station at a work place. Lately there has been a widespread EV adoption by consumers, which is only expected to increase manifold in near future [3, 4]. Essentially such an adoption would put more stress on electric utilities particularly at the distribution level as more and more consumers expect to use more energy in the form of electricity. PEV chargers are the devices that transmit

electric energy from grid into the PEV batteries. Currently there are three levels of battery charging techniques available to recharge the PEV batteries, classified as Level 1, Level 2 and Level 3 chargers [5]. Level 1 and 2 are single phase and Level 3 is three phase. Level 1 chargers are standard 120 V/16 A wall outlet and has a corresponding charger rating of 1.8 KW and are primarily located at homes [6]. Level 2 chargers have higher voltages, typically 208-240 V and draws more current up to 80 A. They could be charged at home or at public chargers. They have shorter charging time than Level 1 chargers. Level 3 is a three phase battery charger and has a maximum capacity of 96 KW, rated at 208-600 V/400 A. Generally level 3 chargers are not available in residential areas, because this type of chargers draw much more current than Level 1 and 2 chargers, and hence require very short period of charging time [7, 8]. Of these three levels, only Level 1 and 2 chargers could impact a distribution system in terms of voltage unbalance and transformer overloading.

This study is focused on impact of Level 2 chargers on the residential distribution grid. While the potential societal and economic benefits of PEVs are undeniable, safe and reliable operation of the electrical network is still a primary utility concern due to expected stress on the grid. Thus, understanding and accurately predicting PEV electrical system impact on the grid is important for all the stake holders, namely automotive manufacturers, consumers, and more importantly the utility companies particularly at the distribution level [9].

1.2 PEVs Market and Government Policy

The goal set by the Obama administration is one million plug-in electric vehicles (PEV) on the road by 2015 in the US. This goal is being supported by government incentives and stimulus investments to accelerate market acceptance, including grants and loans to manufacturer

and tax credits to consumers [10]. Projected market penetration of conventional vehicles (CVs), hybrid electric vehicles (HEVs), and PHEVs from 2010 to 2030 is illustrated in figure 1.1 [11-13] with HEVs representing about 15% of the market new vehicle sales when PHEVs were expected to enter the market in 2010. PHEVs could reach a maximum of 10% new vehicle market share by 2015 timeframe [9].

Figure 1.1 Projected New Vehicle Market Share Categories [9]

In addition, various U.S state governments have passed their own laws to promote PEVs by providing grants for electrical vehicle research, funding for PEV charging infrastructure, and loans or tax credits for “green technology” related businesses. PEVs cost more than a comparable conventional vehicle. The difference in cost is currently offset by Tax credit from the government. The Tax Credit provides a \$2,500 for vehicles with batteries of at least four

kWh. With the size of the battery credit steps up to a maximum of \$7,500 as battery size is major determinant of cost for PEV [14].

1.3 Statement of the Problem

From the consumer point of view, the PEV batteries have to be charged so the driver can drive off with a fully-charged battery. That brings in the question of place and time for charging these batteries. There are two main places where the PEV batteries can be recharged: either on a corporate or public car park, or at home. Irrespective of the location, uncoordinated power consumption that can result from this charging activity on a local scale can lead to grid problems. The charging of PEVs has an impact on the distribution grid because these vehicles consume a large amount of electrical energy and this demand of electrical power can lead to extra large and undesirable peaks in the energy consumption. The impact of these extra single phase electrical loads can be analyzed in terms of power losses and voltage unbalances [15].

From the distribution system operator point of view, the power losses during charging are of an economic concern and transformer and feeder overloads are of a reliability and safety concern [16]. In addition, power quality (e.g., voltage profile, unbalance, harmonics, etc.) is essential to the distribution grid operator as well as to grid customers. Voltage deviations are a definite power quality concern [17].

In this regard, measuring these voltage imbalances over a distribution grid due to wider consumption of electricity for charging PEVs is central in finding a solution such as "smart" or "coordinated charging".

1.4 Thesis Organization

The primary objective of this study is to assess the impact of PEV battery charging on a residential distribution system, where the impact has been reported in terms of voltage unbalance and transformer overloading.

In the chapter 1, general introduction of PEVs, their market penetration, and specific statement of problem have been presented. Chapter 2 of this study contains a review of the literature on types of PEVs, their charging characteristics and their impact on electric grid. The focus of chapter 3 is modeling a distribution system using MATLAB-SIMULINK, with emphasis on components that are modeled such as single-phase distribution transformer, overhead and underground cables, and system breakers.

Chapter 4 consists of the estimation of reactive power consumed by the residential customers based on the load data provided by a power distributor. In chapter 5, the testing and simulation of the developed model of 12.47 KV distribution system has been presented along with comparison between simulated voltages and actual voltages (as provided by the power distributor). Various levels of PEV penetrations and voltage unbalance calculations are also shown in chapter 5.

Summary of the study findings and proposed recommendations to mitigate the potential impact of PEV on the distribution system and overall conclusions of this study are presented in Chapter 6.

CHAPTER 2

LITERATURE REVIEW

2.1 Types of Plug-in Electric Vehicles

The drivetrain architecture of a Plug-in Electric Vehicle (PEV) typically includes the following components; an electric motor, a battery and a device to charge the battery through connecting to the electricity grid [4]. Depending on which of these components exist in and different drivetrain architectures, Plug-in Electric Vehicle (PEV) can be divided into BEVs, PHEVs, and Extended range electric vehicles (EREVs).

2.1.1 Battery Electric Vehicles

BEVs are pure electric vehicles i.e. with no internal combustion engine and require recharging at the end of their designed driving range. Given their complete dependency on battery, BEVs generally have the highest all-electric range (e.g., 60-100 miles) and the largest battery capacity (e.g., 25-35 kWh) [18]. Battery recharging time varies with the type and capacity of the EV battery and the output capacity of charger. Examples of BEV include Nissan Leaf and Tesla Roadster. Battery electric vehicle is often referred to as a zero-emission vehicle (ZEV), but this can be misleading as the entire energy cycle, including power plants or other generation units needed to produce electrical energy, must be considered to determine the emissions.

2.1.2 Plug-in Hybrid Electric Vehicles

A PHEV is commonly equipped with a drivetrain that contains an internal combustion engine, an electrical motor, a battery storage system and means of recharging the battery system from an external source of electricity [19]. Its battery capacity is usually several kWhs or more, to power the vehicle in all electric drive mode [20] and its internal combustion engine can be engaged to extend its drive range when the battery's charge is not sufficient [21]. The modified Toyota Prius with plug-in capability is an example of PHEV.

Compared to BEVs, PHEVs have an extended range because they contain a small internal combustion engine for longer distances, and PHEVs also have a lower purchase price since the battery pack is the most expensive part of electric vehicles and BEV's battery pack is comparatively larger than that of PHEV. Larger battery pack of BEV's is more expensive and demands longer time to charge [22].

2.1.3 Extended-Range Electric Vehicles

An EREV is similar to a PHEV in terms of drivetrain architecture, i.e. it has an internal combustion engine, an electrical motor, and a battery. However it offers more pure electric driving capability in the initial driving range, referred to as all-electric range (AER). While PHEVs derive most of their power from a gas engine. EREVs are pure electric vehicles that utilize a small combustion generator to generate more electricity and extend the range of the vehicle beyond its battery pack. To realize pure electric driving in all driving conditions, EREVs are equipped with a full-sized traction motor powered by the battery pack. The large battery capacity allows all electric driving range of about 40-60 miles. However EREVs have increased

system cost due to the full-sized traction motor and power requirements for the battery [23]. Chevrolet Volt, built by General Motors is an example of EREV.

2.2 PEV Charging Characteristics

The power needed to charge PEVs vary based on the specific battery pack and charging equipment and therefore it is desirable for the vehicle to control battery charging; currently charging systems are set to provide the maximum available current by default. However the functionality details in standards have been developed for the U.S. through Society of Automotive Engineers (SAE). The common electric vehicle conductive charging system architecture has been defined by SAE J1772 [11]. It covers the general physical, electrical, and performance requirements for the electric vehicle conductive charging system and coupler for use in North America. According to the SAE, the charging methods for electrical vehicle are classified into three types as follows; AC Level 1, AC Level 2 and AC Level 3 [7, 24]

2.2.1 AC Level 1 Charger

AC Level 1 charger uses a standard electrical outlet dedicated at 120V/16 A and has a capacity up to 2 KW, which is the most commonly found outlet in a household. Depending on the initial SOC (State of Charge) and capacity of the battery, Level 1 charging takes about 5-8 hrs to fully charge the vehicle's battery [7, 9] . While these chargers are ideal for overnight residential charging purposes, these are not suitable for quick commercial or public charging purposes due to the time required for the charging.

2.2.2 AC Level 2 Charger

Level 2 charging is done using a 240 V electric outlet, more like residential appliances such as: an electric hair dryer, electric oven or a central air conditioning system. It operates at 208-240V, power demand up to 15 KW and a current level not greater than 80A [7]. Level 2 offers a smaller window of charging time, usually half the requirement of Level 1. Level 2 chargers are commonly found in homes and commercial areas and must be permanently hard-wired cord set into a special box with safety electronics [25] to the premise for EV charging purposes only. Vehicle owners seem likely to prefer Level 2 charging technology owing to its faster charging time and standardized vehicle-to-charger connection availability. This study focuses on voltage unbalance caused by Level 2 battery charging on a distribution system.

Figure 2.1 Level 2 charging station [26]

2.2.3 AC Level 3 Charger

Level 3 is a 3-phase charger and rated at 208-600V AC, maximum current up to 400A and power demand greater than 15-96 KW. Level 3 is commercial fast charging and offers the possibility of charging time about 10-15 mins to fully charge a vehicle battery, depending on the capacity and state of charge of the battery [3, 8]. Naturally these chargers use higher power in comparison with residential charging. A lower power demand of charger is an advantage for utilities, particularly at distribution level seeking to minimize on-peak impact. High power penetration of charging can increase power demand and has the potential to quickly overload local distribution equipment at peak times [27]. Level 2 charging can increase distribution transformer losses, voltage unbalances, harmonic distortion, peak demand, and thermal loading on the distribution system [25]. Table 2.1 shows standard charging ratings for different charging levels.

Table 2.1 PEV charging characteristics for various levels

Type	Nominal Voltage (V)	Max Current (A)	Power level
AC Level 1	120V, 1 phase	16A	2 KW
AC Level 2	208-240V, 1 phase	32A	8 KW
AC Level 3	208-600VAC, 3 phase	400A	15 - 96 KW

The new standard has an SAE J1772 [28] ac charge connector on top and a two-pin dc connector below and is intended to enable either ac or dc fast charging via a single connection, as shown in Figure 2.2.

Figure 2.2 AC/DC Combo Coupler and Receptacle based on SAE 1772 TM [28]

2.3 Impact of PEVs on the electric grid

An electric grid consists of generation, transmission, and distribution systems. The generation system composed of power plants that generate electricity from a variety of sources such as coal, gas, solar, wind etc. The transmission system consists of transmission lines that transfers electricity between generation and distribution systems [29], and it also includes transformers to step up the electricity to the higher voltage. The distribution system mainly consists of substations, and transformers to step down the electricity to a level used by end-use customers; usually 120/240 V for residential customers, and larger voltage levels for some commercial and industrial customers. The impact of PEV charging on the electric grid as a whole is mainly influenced by two aspects; (1) the level of PEV penetration, and (2) the point in time and the duration of PEV charging.

2.3.1 Impact on Generation

A significant amount of increased PEV penetration would immediately result in extra energy requirement that must be generated by a generation system. Given the paucity of storage

availability on an electric grid, it would result in challenge of instantaneous and continuous matching between demand and generation [30]. In addition, uncoordinated PEV charging in terms of time and duration may introduce new peak for the system load, which in turn may result in increased time during which the power plants may have to work at full power and thereby increasing costs and reduced system reliability [31].

2.3.2 Impact on Transmission

With increased PEV penetration, there will be a definite need for increased transmission capacity that is needed to meet the additional energy requirement of PEV charging [22]. Therefore without coordinated charging, the transformers may be overloaded for extended periods. This would result in reduced lifetime of the transformers as well as reliability constraints [32, 33].

2.3.3 Impact on Distribution

PEVs are likely to have more impact on the distribution system than they will have on the generation and the transmission systems. A distribution system can be affected by PEV charging by the same two elements explained above. It is important to know the relationship between the penetration level of PEVs and the components of a distribution system such as feeders, substations, and transformers; as with higher penetration levels of PEVs, the latter may become overloaded. Overloading of the transformer does not immediately result in device failure, but reduces its lifespan [16]. A low-voltage grid is not capable of handling situations where everyone is charging simultaneously. Local demand profiles will change significantly because of such simultaneous or uncoordinated charging. If many PEV owners charge their vehicle

simultaneously in a district, it will have a major impact on local infrastructure and local peak demand. Several studies have concluded [9, 34] that PEVs will influence the distribution grid for certain. The extent of the impact depends on the penetration level of the PEVs and their charging behavior.

2.4 Implications of voltage unbalance

Voltage unbalance is a power quality problem that has a detrimental effect on the performance and efficiency of three phase induction motors. It is frequently encountered in weak networks at the industrial and distribution levels. It is caused by uneven distribution of single-phase loads over the three phases and by asymmetry of impedances over three phase lines. This problem is expected to worsen by PEV battery charging on the distribution system. The definition of voltage unbalance used by the power community is the ratio of negative sequence voltage to the positive sequence voltage [35]. National Electrical Manufacturer Association (NEMA) defines percentage voltage unbalance (%PVU) as the ratio of maximum voltage deviation to the average of three phase voltages.

$$\% \text{ PVU} = \frac{\text{Maximum voltage deviation from the average voltage}}{\text{Average voltage}} \times 100$$

According to NEMA motor standard, a maximum unbalanced voltage up to 1 percent at the motor terminal is allowed. This recommendation is not suitable for all motors with different classes, sizes, and loads [36].

CHAPTER 3

MODELING OF A DISTRIBUTION SYSTEM USING MATLAB - SIMULINK

3.1 Matlab - Simulink Software

A 12.47 KV distribution system in this study has been modeled and tested using Matlab/Simulink/SimPowerSystem (Version 7.12 R2011b), which is a modern design software that allows scientists and engineers to rapidly and easily build models that simulate power systems. The Simulink environment of MATLAB, not only allows the drawing of the circuit topology rapidly, but also the analysis of the circuit which can include its interactions with mechanical, thermal, control, and other disciplines. This is possible because all the electrical parts of the simulation interact with the extensive Simulink modeling library [37]. Simulink/SimPowerSystem has number of advantages over its contemporary simulation software (like PSPICE) due to its open architecture, a powerful graphical user interface and versatile analysis and graphics tools [38].

3.2 Modeled Distribution System

The existing distribution system consists of residential metered and primary metered customers. Like most distribution systems, the modeled system is a radial system, receiving power from a three phase source at 12.47 KV. Figure 3.1 shows a one line diagram of a distribution system provided by a power distributor for this study.

Figure 3.1 One line diagram of the studied distribution system

Figure 3.2 Two sections of one line diagram of the studied system

While the distribution system consists of several sections, this study is based on the first two sections of the system for the household metered customers (as shown in figure 3.2). The distribution system feeds power to the metered customers through a main feeder. The main feeder line consists of several branch lines. The main feeder has overhead (OH) lines and the

branch lines consists of overhead (OH) lines and underground (UG) cables. Each service transformer serves the demand of the metered customers connected to it. The service transformer serves the customers at 480V, 240V and 120V. The modeled system is comprised of total 44 service transformers; of which 41 are single phase (7200-120/240V) and 3 three phase transformers. Single phase transformers ratings range from 15-100 KVA and three phase transformers sizes ranging from 15-500 KVA.

Figure 3.3 MATLAB-SIMULINK model of studied system

As shown in the figure 3.3, subsystems section 1 and section 2, are comprised of a primary and a secondary distribution feeder lines. The detailed view of the subsystem section 1 and 2 are shown in figure 3.5 and figure 3.6 respectively. As shown in figure 3.4, the modeled distribution system includes two circuit breakers one is located nearer to the substation bank and the other one is located at the end of the section 2

Figure 3.6 Simulink distribution system layout of subsystem section 2

3.3 Overhead lines and Underground cables

The distribution system is comprised of both OH lines and UG cables. The over head line conductor sizes ranging from 1033 aerial primary feeder to 4/0 aluminum. In the Simulink

modeled system, OH lines and UG cables are represented by three phase pie section block as shown in figure 3.7. In this study, the transmission line is represented by its pie equivalent circuit. The pie model consists of one set of RL series elements connected between sending and receiving end terminals and two sets of shunt capacitances lumped at both ends of the line [37].

Figure 3.7 Three phase pie section line block [37]

Positive sequence and zero sequence impedances and admittances of the lines are provided by the power distributor are shown in table 3.1. The conductor impedance values are given in ohms/feet. However as PI model block requires the parameters to be in ohms/kilometers, the necessary conversion was performed.

Table 3.1 Impedances of Overhead Lines

Size of the conductor	Material	Positive Sequence Impedance (ohms/1000ft)		Zero Sequence Impedance (ohms/1000ft)		Positive Sequence Admittance (us/1000ft)		Zero Sequence Admittance (us/1000ft)	
		R1	X1	R0	X0	G1	B1	G0	B0
1033	Aerial	0.01777	0.1157	0.1233	0.3735	0	1.354	0	0.6314
1033 AL	Aluminum	0.01800	0.1166	0.1138	0.3924	0	1.349	0	0.5870
1/0 AL	Aluminum	0.16770	0.1437	0.2731	0.4014	0	1.086	0	0.5666
4/0 AL	Aluminum	0.08376	0.1356	0.1892	0.3934	0	1.155	0	0.5847

Table 3.2 shows the calculated values for positive and zero sequence resistances, inductances and capacitances in S.I units for the length of the conductor line. The 1/0 ALXLP (Aluminum Cross Linked Polyethylene) in table 3.2 represents an underground cable. The values for resistances, inductances and capacitances of this cable are provided by the power distributor.

Table 3.2 Resistances, Inductances and Capacitances of OH lines and UG cables

Size of the conductor	Positive Sequence and Zero Sequence Resistance, Inductance and Capacitance					
	R1 (Ω /km)	R0 (Ω /km)	L1 (H/km)	L0 (H/km)	C1 (F/km)	C0 (μ F/km)
1033 Aerial	0.05830052	0.40452757	0.00100649	0.00324915	0.011778713	0.005492673
1033 Al	0.05905512	0.37335959	0.00101432	0.00341356	0.011735217	0.005106429
1/0 Al	0.55019686	0.89599740	0.00125007	0.00349185	0.009447328	0.004928965
4/0 Al	0.27480315	0.62073492	0.00117961	0.00342226	0.010047573	0.00508642
1/0 AIXLP	0.56000000	0.96140000	0.00064935	0.00069257	0.06885428	0.026584886

3.4 Service Transformers

In the modeled system, most of the service transformers are single phase and modeled as a three winding transformer, the primary side of the transformer is connected to 7.2 KV. The secondary side of the transformer consists of 120/240V. Typical single phase distribution transformer connection diagram shown in figure 3.8. Each service transformer parameters are manually entered on the transformer parameter block. A sample of the transformer parameter block of SimPowerSystems is shown in figure 3.9.

Figure 3.8 Connection diagram of a single phase transformer

Figure 3.9 Sample SimPowerSystems block for the single phase transformer [37]

The modeled distribution system service transformer impedances provided by the power distributor, are listed by their rating as shown in the table 3.3.

Table 3.3 Service transformer Impedances by rating

Transformer Rating (KVA)	Positive Sequence Impedance (%Z1)	Zero Sequence Impedance (%Z0)	X/R Ratio
15	2.5	2.5	4
15 (3 phase)	4.5	4.5	4
25	4.5	4.5	4
37	4.5	4.5	4
50	4.5	4.5	4
75	3.0	3.0	4
100	4.5	4.5	4
225	4.5	4.5	4
500	3.94	3.94	10

For a single phase transformer supplying single-phase service, the full load current in amperes is calculated as follows:

$$\text{Full load current} = \frac{\text{Transformer KVA rating} \times 1000}{\text{Voltage Rating}}$$

Table 3.4 below lists full load current, shows the list of transformers used in this study.

Table 3.4 Nominal current ratings of single-phase transformers

Transformer Rating (KVA)	Current at 7200 V (Amps)	Current at 120 V (Amps)	Current at 240 V (Amps)
15	2.08	125.00	62.50
25	3.47	208.33	104.17
37	5.14	308.33	154.17
50	6.94	416.67	208.33
75	10.40	625.00	312.50
100	13.90	833.33	416.67

3.5 Distribution system load

Fifteen minutes intervals load data of four days (01/09/2013 - 01/12/2013) for the distribution system are provided by the power distributor. The load data measured at the substation include all residential metered customers and primary metered customers served by the system. Primary metered customers are major customers who purchase bulk energy. However the primary metered customers are not considered in the modeled system for this study because of lack of data for those customers. Figures 3.10 and 3.11 shown below are the active and reactive load profiles of the distribution system respectively.

Figure 3.10 Total Active Power for 4 days

Figure 3.11 Total Reactive Power for 4 days

3.6 Residential Power Demand

Power distributor provided the residential smart metered customers' load data at fifteen minutes intervals of 4 days (01/09/2013 - 01/12/2013) for the modeled system. The provided smart meters data was energy (watt hours) consumed by each residential metered customer. The data is then converted into real power (watts). The estimated reactive power (var) is chapter 4.

3.7 Level 2 battery charger model using MATLAB-SIMULINK

Figure 3.12 Battery charger model using MATLAB-SIMULINK

A level 2 battery charger has been modeled for this study using MATLAB-SIMULINK as shown in figure 3.12. Since level 2 charger is a single-phase AC charger and operated at 208-240V, 32A current rating and power level up to 8 KW, it is necessary to convert the current provided by an external energy source by a rectifier to direct current . The battery component for

this model is sourced from MATLAB-SIMULINK. A simulation has been attempted by integrating the battery charger model with the modeled distribution system in this study. However the simulation has failed due to incompatibility of power electronics component of battery charger with the existing MATLAB-SIMULINK blocks. Hence the battery charger integrated with modeled distribution system has not been considered for this study, however it can be considered for future research.

CHAPTER 4

DISTRIBUTION SYSTEM LOAD DATA ANALYSIS

4.1 Introduction

The studied model for the distribution system is shown in figure 4.1 below. By having total active and reactive load data for the entire system and knowing residential metered customers energy usage for the first two sections, calculations are made to estimate the reactive power consumed by the metered customers for those two sections of the system. Intellirupters A55661 and B51432 in figure 4.1 represents circuit breakers CB1 and CB2 respectively in the Simulink modeled system. The data provided at CB1 represents the load data for the entire system, whereas the data at CB2 represents the load data for the later part of the system. Given that the load data for the sections 1 and 2 that are part of this study, essentially represented by the difference of load data at CB1 and CB2.

Figure 4.1 Two sections of one line diagram of studied system

Out of four days (01/09/2013 - 01/12/2013) load profile data, one day's (01/10/2013) load data has been selected for testing the Simulink modeled system and the simulation results are compared with real load data provided by the power distributor for that particular day. The objective of this study is to assess the impact of PEV on the distribution system during peak and off peak load demand. From the provided load data at CB1, it is observed that the peak demand occurred at around 2.30 PM and off peak demand at 6.30 AM on 01/10/2013 as shown in figure 4.2 & 4.3.

Figure 4.2 True Active Power at CB1

Figure 4.3 True Reactive Power at CB1 on 01/10/2013

4.2 Reactive Power Calculations

Since the peak and off-peak true active power and true reactive power for CB1 have been observed at 2:30 PM and 6:30 AM respectively, the true active power and true reactive power for CB2 observed at those same time points have been taken into consideration to estimate the reactive power consumed by the residential customers (Section 1 & 2 of the figure 4.1). The total active and reactive power consumed by the modeled system are calculated as below;

Total Active Power at CB1 - Total Active Power at CB2 = Total Active Power Consumed by the residential customers and primary metered customers. -----→ (1)

Total Reactive Power at CB1 - Total Reactive Power at CB2 = Total Reactive Power Consumed by the residential customers and primary metered customers. -----→ (2)

By substituting the active and reactive power values at peak and off-peak power demands for CB1 and CB2 in equations (1) and (2) respectively, the resultant differences between CB1 and CB2 are presented below in the table 4.1.

Table 4.1 Peak and Off-Peak Active and Reactive Powers for CB1, CB2

Type of Load	Date: 01/10/2013	CB1	CB2	CB1 - CB2
True Active Power (MW)	Peak (2:30 PM)	4.026	1.303	2.723
	Off-Peak (6:30 AM)	2.702	1.048	1.654
True Reactive Power (MVAR)	Peak (2:30 PM)	0.494	0.224	0.270
	Off-Peak (6:30 AM)	0.315	0.220	0.095

4.3 Active to Reactive Power Ratio at Peak and Off-Peak

Table 4.2 Active to Reactive Power Ratio of the system

Date: 01/10/2013	Type of Load	CB1 - CB2	Active to Reactive Power Ratio
Peak (2:30 PM)	True Active Power (MW)	2.723	10.085
	True Reactive Power (MVAR)	0.270	
Off Peak (6:30 AM)	True Active Power (MW)	1.654	17.410
	True Reactive Power (MVAR)	0.095	

As presented in the table 4.2 above, at the peak, the ratio of active power to reactive power = $2.723/0.27 = 10.085$, and at the off-peak, the ratio of active power to reactive power = $1.654/0.095 = 17.41$.

These peak and off-peak ratios of active power to reactive power (10.085, 17.41) include residential customers as well as primary customers. Due to lack of the load data of primary metered customers, for the purpose of this study, above estimated ratios of active power to reactive power are assumed to be only that of residential customers i.e. section 1 and 2 of modeled system (figure 4.1). With that assumption, based on these ratios of active power to reactive power, the reactive power consumed by the residential customers is calculated. Table 4.3 lists total real and reactive power for all service transformers (at peak and off-peak) and number of customers connected to the distribution transformers for section 1 and section 2 of the modeled system (figure 4.1).

Table 4.3 Real and Reactive power demands for all service transformers

Transformer Labeling	Transformer KVA Rating	No. of customers connected	Peak demand (2.30PM)		Off-Peak demand (6.30AM)	
			Real Power (KW)	Reactive Power (KVAR)	Real Power (KW)	Reactive Power (KVAR)
OW5006	50	1	1.094	0.108	0.986	0.057
OW51142	25	2	8.800	0.873	8.112	0.466
OW51325	15	1	0.252	0.025	0.288	0.017
OW5562	37	8	6.412	0.636	9.940	0.571
OW5567	37	1	0.652	0.065	2.448	0.141
OW5568	25	2	1.072	0.106	0.980	0.056
OW5656	25	4	7.536	0.747	1.760	0.101
OW5657	25	1	0.180	0.018	5.508	0.316
OW5658	25	7	3.088	0.306	13.328	0.766
OW5666	37	9	13.068	1.296	4.488	0.258
OW5739	37	2	1.472	0.146	2.192	0.126
OW5741	37	3	4.236	0.420	3.916	0.225
OW5800	15	1	0.272	0.027	0.032	0.002
OW5880	37	2	0.268	0.027	1.016	0.058
OW5882	25	1	3.484	0.345	0.700	0.040
OW5883	25	2	1.348	0.134	2.848	0.164
OW5884	37	1	0.448	0.044	0.392	0.023
OW5913	25	1	3.244	0.322	0.448	0.026
OW5915	50	2	1.116	0.111	1.096	0.063
OW5917	37	2	3.592	0.356	2.804	0.161
OW5925	37	2	3.100	0.307	5.876	0.338
OW5P024	37	1	6.404	0.635	0.248	0.014
OW5P025	37	3	5.404	0.536	6.540	0.376
OW5P026	50	3	5.072	0.503	7.588	0.436
OW5P109	100	18	24.888	2.468	19.348	1.111
OW5P110	100	18	22.152	2.197	21.960	1.261
OW5P111	100	18	15.412	1.528	19.988	1.148
OW5P112	100	18	12.556	1.245	25.560	1.468
OW5P232	500	1	0.264	0.026	0.128	0.007
OW5932	50	2	1.116	0.111	1.096	0.063
OW5502	50	3	1.094	0.108	0.986	0.057
OW51593	50	2	1.116	0.111	1.096	0.063
OW5566	15	1	0.272	0.027	0.032	0.002
OW5557	25	4	8.800	0.873	8.112	0.466
OW5558	25	1	1.072	0.106	0.980	0.056
OW5P018	75	1	1.304	0.129	4.896	0.281
OW5683	37	1	6.412	0.636	9.940	0.571
OW5835	37	9	0.652	0.065	2.448	0.141
OW5838	37	3	13.068	1.296	4.488	0.258
OW51657	25	7	7.536	0.747	1.760	0.101
OW5839	50	3	5.072	0.503	7.588	0.436
OW5840	25	2	0.180	0.018	5.508	0.316
OW5P165	225	1	0.325	0.032	0.156	0.009
OW5P244	75	2	0.756	0.075	1.620	0.093

Figures 4.4 and 4.5 are the graphical representation for total real and reactive power of each distribution transformer modeled in the system, for peak and off-peak power demands. From the figure 4.4, it is observed that total real power demand for some service transformers are higher at 6.30AM (off-peak) than at 2.30PM (peak) and vice versa.

Figure 4.4 Total real power of each service transformer at peak and off-peak demand

Similarly from the figure 4.5, it is observed that total reactive power demand for some service transformers are higher at 6.30AM (off-peak) than at 2.30PM (peak) and vice versa.

Figure 4.5 Total reactive power of each service transformer at peak and off-peak demand

CHAPTER 5

CASE STUDY AND SIMULATION RESULTS

As discussed in previous chapters, the modeled distribution system consists of two sections as shown in figure 5.1, which is a simplified drawing of the Simulink modeled distribution system. This system has a total of 177 customers, of which 174 customers are on single-phase and 3 customers are on three-phase for their daily use of electricity served by the 161/12.47 KV distribution substation. In order to assess the impact of PEV battery charging on the distribution system, various locations have been selected to measure the three-phase voltages based on the number of customers connected to the modeled 12.47 KV distribution system at each of the selected locations.

Figure 5.1 Simplified diagram of the modeled distribution system.

In figure 5.1, L1, L2, L3, and L4 indicates the locations where the three-phase voltage and current measurements are being observed, because each of these locations have more than 10 customers connected to the sub branch line. The dotted lines in the figure 5.1 indicate underground cables. Also, three-phase measurements were observed at CB1 and CB2 to identify voltage variations at the beginning and at the end of the modeled system.

5.1 Simulink model testing without PEV penetration

5.1.1 Voltages and currents at peak demand

In order to establish a benchmark from which to compare PEV impact, the modeled distribution system is analyzed with no PEVs first. The distribution system is modeled for both peak and off-peak power demand. Figures 5.2 and 5.3 show three-phase peak voltages and currents measured at the beginning of the system (CB1) for peak demand (2.30 PM) on 01/10/2013.

Figure 5.2 Measured three-phase voltages at CB1 of the system at peak demand

Figure 5.3 Measured three-phase currents at CB1 of the system at peak demand

Table 5.1 has the measured and actual voltages of phase to ground and phase currents at peak demand on 01/10/2013. Actual voltages shown in table 5.1 are provided by power distributor for the modeled distribution system. All voltages and currents shown in table 5.1 are measured in root mean square (RMS).

Table 5.1 Measured and actual phase voltages and currents at CB1 at peak demand

At peak demand for CB1	Phase to ground voltages (KV)			Phase currents (A)		
	Va	Vb	Vc	Ia	Ib	Ic
Measured Values	7.112	7.113	7.117	189	187	178
Actual Values	7.141	7.115	7.094	197	195	186

Figures 5.4 and 5.5 show simulation results of three phase voltages and currents for CB2 at peak (2.30 AM) demand on 01/10/2013 for the modeled system respectively.

Figure 5.4 Measured three-phase voltages at CB2 of the system at peak demand

Figure 5.5 Measured three-phase currents at CB2 of the system at peak demand

Table 5.2 shows the measured and actual voltages of phase to ground and phase currents for peak demand on 01/10/2013.

Table 5.2 Measured and actual phase voltages and currents at CB2 at peak demand

At peak demand for CB2	Phase to ground rms voltages (KV)			Phases currents (A)		
	Va	Vb	Vc	Ia	Ib	Ic
Measured Values	7.066	7.087	7.081	60.1	60.26	60.21
Actual Values	7.122	7.095	7.090	58.0	79.00	52.00

5.1.2 Voltages and currents at off-peak demand

Figures 5.6 and 5.7 show measured three-phase peak voltages and currents at the beginning of the section (CB1) for off-peak power demand (6.30 AM) on 01/10/2013.

Figure 5.6 Measured three-phase voltages at CB1 of the system at off-peak demand

Figure 5.7 Measured three-phase currents at CB1 of the system at off- peak demand

Table 5.3 shows the measured and actual voltages of phase to ground and phase currents at off-peak demand on 01/10/2013.

Table 5.3 Measured and actual phase voltages and currents at CB1 at off-peak demand

At off-peak demand for CB1	Phase to ground voltages (KV)			Phase currents (A)		
	Va	Vb	Vc	Ia	Ib	Ic
Measured Values	7.139	7.141	7.145	130.25	127.17	117.23
Actual Values	7.120	7.100	7.069	135.00	131.00	123.00

Figures 5.8 and 5.9 show simulation results of three phase voltages and currents for CB2 at off-peak (6.30 AM) demand on 01/10/2013 for the modeled system respectively.

Figure 5.8 Measured three-phase voltages at CB2 of the system at off- peak demand

Figure 5.9 Measure three-phase currents at CB2 of the system at off- peak demand

Table 5.4 shows the measured and actual values of phase to ground voltages and phase to ground currents at off-peak demand on 01/10/2013.

Table 5.4 Measured and actual phase voltages and currents at CB2 at off-peak demand

At off-peak demand For CB2	Phase to ground rms voltages (KV)			Phase to ground rms currents (A)		
	Va	Vb	Vc	Ia	Ib	Ic
Measured Values	7.106	7.127	7.124	48.93	49.01	49.06
Actual Values	7.106	7.086	7.068	48.00	62.00	43.00

5.2 Simulink model testing with PEV penetration

In this section, the modeled distribution system is being tested with Level 2 charging load during peak and off-peak power demand. As discussed in chapter 2, Level 2 charger has ratings of 240V, 32 A and 7.680 KW. A single-phase level 2 charger can have significant impact on the distribution system, which is measured in terms of voltage unbalance. According to IEEE standards, voltage unbalance is defined as the ratio of maximum voltage deviation from the

average phase voltage to the average phase voltage [39, 40]. It is also known as the phase voltage unbalance rate (PVUR), and is given by

$$\% \text{ PVUR} = \frac{\text{Maximum voltage deviation from the average phase voltage}}{\text{Average phase voltage}} \times 100$$

The IEEE uses the same definition of voltage unbalance as NEMA, the only difference being that the IEEE uses phase voltages rather than line-to-line voltages. In this study, percentage voltage unbalance (VU) calculations have been according to IEEE standards.

As discussed in initial section of this chapter, there are 174 single-phase residential customers utilizing electricity from the modeled distribution system. Out of these 174 customers, 81 customers have been drawing power from phase-A, 81 customers from phase-B, and 12 customers from phase-C.

5.2.1 Studied system with 10% PEV penetration

For 10% of PEV load, it is assumed that there are 17 customers (~10% of 174) have a PEV in that neighborhood and recharge their PEV batteries. In this instance, for 10% of penetration level in simulation, out of 17 PEVs, 8 PEVs' load is added to the phase-A, 8 PEVs' load is added to the phase-B, and 1 PEV load is added to the phase-C.

Figure 5.10 Distribution system model with 10% of PEV penetration

Figure 5.10 shows distribution system model with 10% of penetration level, where the locations of PEV charging in each phase are shown with car symbols along with number of PEVs. Each phase in figure 5.10 can be identified based on ending character of transformers (example: The transformer "T/F_A" is in Phase-A).

Table 5.5 list the measured phase voltages, calculated voltage deviation, and percentage voltage unbalance for 10% penetration level of PEVs for both peak and off-peak power demand for all locations in the simulated system (CB1, L1, L2, L3, L4, CB2).

Table 5.5 Phase voltages at peak and off-peak demand for 10% penetration of PEVs

PEV Penetration Level	Power Demand			CB1	Location1	Location2	Location3	Location4	CB2
10%	Peak	Phase Voltages (V)	VA	7109.01	7079.03	7071.06	7067.06	7059.25	7057.80
			VB	7109.73	7092.71	7088.25	7084.61	7079.27	7088.66
			VC	7117.27	7101.14	7098.18	7096.43	7090.12	7077.80
		Average Voltage (V)		7112.01	7090.96	7085.83	7082.70	7076.21	7074.76
		Maximum voltage deviation (V)		5.268	11.931	14.768	15.64	16.961	16.952
		% Voltage Unbalance		0.074	0.168	0.208	0.221	0.239	0.239
	Off-Peak	Phase Voltages (V)	VA	7135.93	7114.94	7108.81	7105.19	7098.32	7097.10
			VB	7137.36	7131.29	7129.06	7126.07	7122.10	7129.21
			VC	7145.30	7138.31	7137.11	7135.90	7130.44	7120.86
		Average Voltage (V)		7139.53	7128.18	7125.02	7122.39	7116.95	7115.72
		Maximum voltage deviation (V)		5.766	13.236	16.206	17.199	18.63	18.623
		% Voltage Unbalance		0.081	0.186	0.227	0.241	0.262	0.262

For 10% penetration level of PEVs, following deviations are observed from the beginning of simulated system (CB1) to the end of simulated system (CB2) at both the peak and off-peak demands.

At peak demand;

The increase in Maximum Voltage Deviation(V) from CB1 to CB2 = $16.952 - 5.268 = 11.684$ V

The increase in %Voltage Unbalance from CB1 to CB2 = $0.239 - 0.074 = 0.165$

At off-peak demand;

The increase in Maximum Voltage Deviation(V) from CB1 to CB2 = $18.623 - 5.766 = 12.857$ V

The increase in %Voltage Unbalance from CB1 to CB2 = $0.262 - 0.081 = 0.181$

From the above, the increases in Maximum Voltage Deviation and %Voltage Unbalance from CB1 to CB2 are almost similar at peak and off-peak demand for 10% level of PEV penetration.

5.2.2 Studied system with 30% PEV penetration

For 30% of PEV load, it is assumed that there are 51 customers (~30% of 174) have a PEV in that neighborhood and recharge their PEV batteries. In this instance, for 30% of penetration level in simulation, out of 51 PEVs, 24 PEVs' load is added to the phase-A, 24 PEVs' load is added to the phase-B, and 3 PEVs load is added to the phase-C.

Figure 5.11 Distribution system model with 30% of PEV penetration

Figure 5.11 shows distribution system model with 30% of penetration level, where the locations of PEV charging in each phase are shown with car symbols along with number of

PEVs. Each phase in figure 5.11 can be identified based on ending character of transformers (example: The transformer "T/F_A" is in Phase-A).

Tables 5.6 list the measured phase voltages, calculated voltage deviation, and percentage voltage unbalance for 30% penetration level of PEVs for both peak and off-peak power demand for all locations in the simulated system (CB1, L1, L2, L3, L4, CB2).

Table 5.6 Phase voltages at peak and off-peak demand for 30% penetration of PEVs

PEV Penetration Level	Power Demand			CB1	Location1	Location2	Location3	Location4	CB2
30%	Peak	Phase Voltages (V)	VA	7101.68	7064.26	7053.91	7049.18	7041.02	7039.57
			VB	7102.26	7087.14	7083.12	7078.62	7073.16	7091.48
			VC	7116.29	7102.39	7100.20	7099.13	7092.94	7071.60
		Average Voltage		7106.74	7084.60	7079.08	7075.65	7069.04	7067.58
		Maximum voltage deviation		9.55	20.34	25.16	26.46	28.02	28.00
		% Voltage Unbalance		0.134	0.287	0.355	0.374	0.396	0.396
	Off-Peak	Phase Voltages (V)	VA	7128.48	7099.98	7091.43	7087.07	7079.98	7078.76
			VB	7129.83	7125.88	7124.12	7120.28	7116.47	7131.73
			VC	7144.32	7139.49	7139.12	7138.52	7132.96	7115.22
		Average Voltage		7134.24	7121.78	7118.22	7115.29	7109.80	7108.57
		Maximum voltage deviation		10.10	21.80	26.79	28.21	29.82	29.81
		% Voltage Unbalance		0.142	0.306	0.376	0.397	0.419	0.419

For 30% penetration level of PHEVs, following deviations are observed from the beginning of simulated system (CB1) to the end of simulated system (CB2) at both the peak and off-peak demands.

At peak demand;

The increase in Maximum Voltage Deviation from CB1 to CB2 = $28.006 - 9.55 = 18.456$ V

The increase in %Voltage Unbalance from CB1 to CB2 = $0.396 - 0.134 = 0.262$

At off-peak demand;

The increase in Maximum Voltage Deviation (V) from CB1 to CB2 = $29.812 - 10.109 = 19.7 \text{ V}$

The increase in %Voltage Unbalance from CB1 to CB2 = $0.419 - 0.142 = 0.277$

From the above, the increases in Maximum Voltage Deviation (V) and %Voltage Unbalance from CB1 to CB2 are almost similar at peak and off-peak demand for 30% level of PEV penetration. However from 10% level of PEV penetration, there is a significant increase (>50%) in the differences between CB1 and CB2. For example: The difference in increase in Maximum Voltage Deviation from CB1 to CB2 at 30% level of PEV penetration at peak demand (18.456 V) and at 10% level of PHEV penetration (11.684 V) is 6.772 V.

5.2.3 Studied system with 50% PEV penetration

Figure 5.12 Distribution system model with 50% of PEV penetration

For 50% of PEV load, it is assumed that there are 87 customers (50% of 174) have a PEV in that neighborhood and recharge their PEV batteries. In this instance, for 50% of penetration

level in simulation, out of 87 PEVs, 40 PEVs' load is added to the phase-A, 41 PEVs' load is added to the phase-B, and 6 PEVs load is added to the phase-C. Figure 5.12 shows distribution system model with 50% of penetration level, where the locations of PEV charging in each phase are shown with car symbols along with number of PEVs. Each phase in figure 5.12 can be identified based on ending character of transformers (example: The transformer "T/F_A" is in Phase-A).

Table 5.7 list the measured phase voltages, calculated voltage deviation, and percentage voltage unbalance for 50% penetration level of PEVs for both peak and off-peak power demand for all locations in the simulated system (CB1, L1, L2, L3, L4, CB2).

Table 5.7 Phase voltages at peak and off-peak demand for 50% penetration of PEVs

PEV Penetration Level	Power Demand			CB1	Location1	Location2	Location3	Location4	CB2
50%	Peak	Phase Voltages (KV)	VA	7094.424	7050.019	7037.273	7031.041	7020.987	7019.549
			VB	7094.866	7081.291	7077.707	7072.955	7068.919	7092.325
			VC	7114.866	7102.936	7101.580	7100.835	7093.779	7067.438
		Average Voltage		7101.385	7078.082	7072.187	7068.277	7061.228	7059.771
		Maximum voltage deviation		13.481	28.063	34.913	37.236	40.242	40.221
		% Voltage Unbalance		0.19	0.396	0.494	0.527	0.57	0.57
	Off-Peak	Phase Voltages (KV)	VA	7121.093	7085.254	7074.208	7068.297	7059.022	7057.805
			VB	7122.37	7120.225	7118.953	7114.854	7112.393	7132.717
			VC	7142.898	7140.043	7140.518	7140.257	7133.948	7111.138
		Average Voltage		7128.787	7115.174	7111.226	7107.803	7101.788	7100.553
		Maximum voltage deviation		14.111	29.92	37.018	39.506	42.765	42.748
		% Voltage Unbalance		0.198	0.421	0.521	0.556	0.602	0.602

For 50% penetration level of PEVs, following deviations are observed from the beginning of simulated system (CB1) to the end of simulated system (CB2) at both the peak and off-peak demands.

At peak demand;

The increase in Maximum Voltage Deviation (V) from CB1 to CB2 = $40.221 - 13.48 = 26.74$ V

The increase in %Voltage Unbalance from CB1 to CB2 = $0.57 - 0.19 = 0.38$

At off-peak demand;

The increase in Maximum Voltage Deviation (V) from CB1 to CB2 = $42.748 - 4.111 = 28.637$ V

The increase in %Voltage Unbalance from CB1 to CB2 = $0.602 - 0.198 = 0.404$ V

From the above, the increases in Maximum Voltage Deviation and %Voltage Unbalance from CB1 to CB2 vary slightly at peak and off-peak demand for 50% level of PEV penetration. In addition, from 30% level of PEV penetration, there is an increase observed in the differences between CB1 and CB2 at peak and off-peak demand.

5.2.4 Simulink model with 60% PEV penetration

For 60% of PEV load, it is assumed that there are 104 customers (~60% of 174) have a PEV in that neighborhood and recharge their PEV batteries. In this instance, for 60% of penetration level in simulation, out of 104 PEVs, 49 PEVs' load is added to the phase-A, 48 PEVs' load is added to the phase-B, and 7 PEVs load is added to the phase-C. Figure 5.13 shows distribution system model with 60% of penetration level, where the locations of PEV charging in each phase are shown with car symbols along with number of PEVs. Each phase in figure 5.13 can be identified based on ending character of transformers (example: The transformer "T/F_A" is in Phase-A).

Table 5.8 list the measured phase voltages, calculated voltage deviation, and percentage voltage unbalance for 60% penetration level of PEVs for both peak and off-peak power demand for all locations in the simulated system (CB1, L1, L2, L3, L4, CB2).

For 60% penetration level of PEVs, following deviations are observed from the beginning of simulated system (CB1) to the end of simulated system (CB2) at both the peak and off-peak demands.

At peak demand;

The increase in Maximum Voltage Deviation (V) from CB1 to CB2 = $48.077 - 15.553 = 32.524$ V

The increase in %Voltage Unbalance from CB1 to CB2 = $0.681 - 0.219 = 0.462$

At off-peak demand;

The increase in Maximum Voltage Deviation from CB1 to CB2 = $51.264 - 16.206 = 35.058$ V

The increase in %Voltage Unbalance from CB1 to CB2 = $0.722 - 0.227 = 0.495$ V

From the above, the increases in Maximum Voltage Deviation and %Voltage Unbalance from CB1 to CB2 vary at peak and off-peak demand for 60% level of PEV penetration. In addition, from 50% level of PEV penetration, there is an increase observed in the differences between CB1 and CB2 at peak and off-peak demand.

As shown in above table 5.9, almost all the Phase-B transformers in simulated system are either overloaded (measured currents in red colored cells) or close to be overloaded (measured currents in orange colored cells) by the PEV penetration level of 60%. The ratings against which these loads are compared are highlighted in blue colored cells.

Table 5.9 Rated and Measured Currents for Phase-B Transformers in the simulated system

Phase	Power demand	Transformer KVA rating	No. of Customers Connected	Rated Current at 240V (Amps)	Measured Current at 240V (Amps) At 10% PEV penetration	Measured Current at 240V (Amps) At 30% PEV penetration	Measured Current at 240V (Amps) At 50% PEV penetration	Measured Current at 240V (Amps) At 60% PEV penetration
B	Peak	37	9	154.17	80.190	141.52	141.52	171.82
		100	18	416.67	214.98	307.14	398.59	428.86
		100	18	416.67	198.30	290.59	382.17	412.48
		100	18	416.67	157.13	280.53	402.60	463.12
		100	18	416.67	139.66	232.41	385.44	446.02
	Off-peak	37	9	154.17	27.730	27.710	151.78	151.78
		100	18	416.67	181.99	305.99	398.01	458.92
		100	18	416.67	197.98	321.81	413.72	444.07
		100	18	416.67	185.89	309.81	401.77	462.62
		100	18	416.67	219.95	343.50	404.60	495.86

Given that it has been deemed for simulation that no more PEV loads can be added to Phase - B for additional levels of PEV penetration, i.e. during the 70% and 80% PEV penetration levels, the number of PEVs added to Phase - B remain constant at 48.

5.2.5 Studied system with 70% PEV penetration

For 70% of PEV load, it is assumed that there are 122 customers (~70% of 174) have a PEV in that neighborhood and recharge their PEV batteries. In this instance, for 70% of penetration level in simulation, out of 122 PEVs, 64 PEVs' load is added to the phase-A, 48 PEVs' load is added to the phase-B (same as at 60% penetration level), and 10 PEVs load is added to the phase-C.

Figure 5.14 Distribution system model with 70% of PEV penetration

Figure 5.14 shows distribution system model with 70% of penetration level, where the locations of PEV charging in each phase are shown with car symbols along with number of PEVs. Each phase in figure 5.14 can be identified based on ending character of transformers (example: The transformer "T/F_A" is in Phase-A).

Table 5.9 list the measured phase voltages, calculated voltage deviation, and percentage voltage unbalance for 70% penetration level of PEVs for both peak and off-peak power demand for all locations in the simulated system (CB1, L1, L2, L3, L4, CB2).

Table 5.10 Phase voltages at peak and off-peak demand for 70% penetration of PEVs

PEV Penetration Level	Power Demand			CB1	Location1	Location2	Location3	Location4	CB2
70%	Peak	Phase Voltages (KV)	VA	7079.695	7021.441	7004.331	6995.801	6981.459	6980.02
			VB	7091.011	7087.645	7086.564	7082.330	7080.233	7085.12
			VC	7112.217	7096.153	7094.765	7094.107	7086.556	7078.73
		Average Voltage		7094.308	7068.413	7061.887	7057.412	7049.416	7047.96
		Maximum voltage deviation		17.909	46.972	57.556	61.612	67.957	67.932
		% Voltage Unbalance		0.252	0.665	0.815	0.873	0.964	0.964
	Off-Peak	Phase Voltages (KV)	VA	7105.309	7052.781	7036.366	7027.333	7012.374	7011.16
			VB	7118.477	7127.993	7129.957	7126.819	7126.873	7125.64
			VC	7140.687	7134.027	7134.146	7133.801	7126.862	7125.60
		Average Voltage		7121.491	7104.934	7100.156	7095.985	7088.703	7087.47
		Maximum voltage deviation		19.196	52.153	63.79	68.651	76.329	76.307
		% Voltage Unbalance		0.27	0.734	0.898	0.967	1.077	1.077

For 70% penetration level of PEVs, following deviations are observed from the beginning of simulated system (CB1) to the end of simulated system (CB2) at both the peak and off-peak demands.

At peak demand;

The increase in Maximum Voltage Deviation from CB1 to CB2 = $67.932 - 17.909 = 50.023$ V

The increase in %Voltage Unbalance from CB1 to CB2 = $0.964 - 0.252 = 0.712$

At off-peak demand;

The increase in Maximum Voltage Deviation from CB1 to CB2 = $76.307 - 19.196 = 57.111$ V

The increase in %Voltage Unbalance from CB1 to CB2 = $1.077 - 0.27 = 0.807$ V

From the above, the increases in Maximum Voltage Deviation and %Voltage Unbalance from CB1 to CB2 vary significantly at peak and off-peak demand for 70% level of PEV

penetration. There is a 10 - 15% difference between peak and off-peak demands, with off-peak increases being greater. In addition, from 60% level of PEV penetration, there is a significant increase (>50%) observed in the differences between CB1 and CB2 at peak and off-peak demand.

5.2.6 Studied system with 80% PEV penetration

For 80% of PEV load, it is assumed that there are 139 customers (~80% of 174) have a PEV in that neighborhood and recharge their PEV batteries. In this instance, for 80% of penetration level in simulation, out of 139 PEVs, 79 PEVs' load is added to the phase-A, 48 PEVs' load is added to the phase-B (same as at 60% penetration level), and 12 PEVs load is added to the phase-C. Figure 5.15 shows distribution system model with 80% of penetration level, where the locations of PEV charging in each phase are shown with car symbols along with number of PEVs. Each phase in figure 5.15 can be identified based on ending character of transformers (example: The transformer "T/F_A" is in Phase-A).

Figure 5.15 Distribution system model with 80 % of PEV penetration

Table 5.10 list the measured phase voltages, calculated voltage deviation, and percentage voltage unbalance for 80% penetration level of PEVs for both peak and off-peak power demand for all locations in the simulated system (CB1, L1, L2, L3, L4, CB2).

Table 5.11 Phase voltages at peak and off-peak demand for 80% penetration of PEVs

PEV Penetration Level	Power Demand			CB1	Location1	Location2	Location3	Location4	CB2
80%	Peak	Phase Voltages (KV)	VA	7071.13	7004.91	6985.404	6975.693	6958.987	6957.56
			VB	7090.84	7095.57	7096.792	7093.188	7092.376	7080.03
			VC	7112.29	7092.82	7090.353	7089.471	7081.461	7090.87
		Average Voltage		7091.42	7064.43	7057.516	7052.784	7044.275	7042.82
		Maximum voltage deviation		20.877	59.52	72.11	77.09	85.29	85.26
		% Voltage Unbalance		0.294	0.843	1.022	1.093	1.211	1.211
	Off-Peak	Phase Voltages (KV)	VA	7097.61	7040.432	7022.654	7013.23	6997.789	6996.57
			VB	7118.37	7135.082	7138.816	7135.95	7136.343	7120.21
			VC	7140.73	7129.934	7129.009	7128.526	7121.424	7135.06
		Average Voltage		7118.90	7101.816	7096.827	7092.568	7085.185	7083.95
		Maximum voltage deviation		21.825	61.384	74.173	79.339	87.397	87.375
		% Voltage Unbalance		0.307	0.864	1.045	1.119	1.234	1.233

For 80% penetration level of PEVs, following deviations are observed from the beginning of simulated system (CB1) to the end of simulated system (CB2) at both the peak and off-peak demands.

At peak demand;

The increase in Maximum Voltage Deviation from CB1 to CB2 = $85.26 - 20.877 = 64.383$ V

The increase in %Voltage Unbalance from CB1 to CB2 = $1.211 - 0.294 = 0.917$

At off-peak demand;

The increase in Maximum Voltage Deviation from CB1 to CB2 = $87.375 - 21.825 = 65.55$ V

The increase in %Voltage Unbalance from CB1 to CB2 = $1.233 - 0.307 = 0.926$ V

From the above, the increases in Maximum Voltage Deviation and %Voltage Unbalance from CB1 to CB2 are almost similar at peak and off-peak demand for 80% level of PEV penetration. However, from 70% level of PEV penetration, there is an increase observed in the differences between CB1 and CB2 at peak and off-peak demand.

Since Phase-A (79 out of 81 customers), and Phase-C (12 out of 12 customers) are almost maxed out the number of PEVs can be added to the simulated system, further levels of penetration (90%, 100%) cannot be simulated in this study. The primary reason behind Phase-A and Phase-C being maxed out is that after 60% penetration level no more customers could have been added to Phase-B.

5.3 Impact of PEV Penetration on Simulated System

As Maximum Voltage Deviation and %Voltage Unbalance are two primary metrics that have been used to assess the impact of increased levels of PEV penetration (10%, 30%, 50%, 60%, 70%, and 80%) in the simulated system for this study. Figures 5.16 and 5.17 respectively present the progression of Maximum Voltage Deviation and %Voltage Unbalance for the CB1 and the CB2 of the simulated system at peak and off-peak power demands.

Figure 5.16 Maximum Voltage Deviation with level of PEV Penetration

From figure 5.16, it can be observed that for the peak and off-peak demands, Maximum Voltage Deviation is constantly increased with every level of increase in PEV penetration, hence displaying a significantly positive correlation between PEV penetration and Maximum Voltage Deviation. Identical pattern can be observed for %Voltage Unbalance from figure 5.17 below, as %Voltage Unbalance is derived from Maximum Voltage Deviation as a proportion of Average Phase Voltage.

Figure 5.17 %Voltage Unbalance with level of PEV Penetration

5.4 Impact of PEV Penetration on one phase

In the simulations conducted on phase A, B, and C of the distribution system with varying penetration of 10-80%, the highest voltage unbalance observed was 1.23%. For comparison purpose an additional study was conducted with 81 PEV's battery load connected to phase A and no PEV penetration on the other two phases. It is observed that the highest voltage unbalance for this case was 1.5% .

CHAPTER 6

CONCLUSION

PEVs are projected to become a means of electrification of road transportation on the heels of technological advances and demand for eco-friendly energy solutions. The adoption of these vehicles will pose a challenge to the existing infrastructure of the electrical grid in terms of generation, transmission, more importantly distribution; as higher penetration of PEVs and their charging in an uncoordinated manner may introduce new peaks into the system, which have the potential to overload electrical distribution components and cause power pollution problems.

This study examines the impacts of PEV battery charging on a 12.47 KV distribution system at various penetration levels of PEVs. An existing residential distribution system is modeled and simulated using MATLAB-SIMULINK software. This study is focused on maximum voltage deviation, percentage voltage unbalance, and service transformers overloading. It has been found that maximum voltage deviation and percentage voltage unbalance are negatively impacted by increased PEV penetration levels in the residential distribution grid. Transformer overload has also been observed for one of the phases of simulated distribution system at a higher penetration level of PEVs.

Since these challenges will be inevitable with projected adoption of PEVs, smart or coordinated charging, grid reinforcements, optimization of electric grid will become indispensable to meet the new energy requirements without straining the infrastructure.

REFERENCES

- [1] G. A. Putrus, P. Suwanapongkarl, D. Johnston, E. C. Bentley, and M. Narayana, "Impact of electric vehicles on power distribution networks," in *Vehicle Power and Propulsion Conference, 2009. VPPC '09. IEEE*, 2009, pp. 827-831.
- [2] C. H. Stephan and J. Sullivan, "Environmental and energy implications of plug-in hybrid-electric vehicles.," *Environ. Sci. Technol.*, vol. 42(4), pp. 1185-1190, 2008.
- [3] M. Brenna, F. Foiadelli, and D. Zaninelli, "Power and energy estimation for Plug-in electric vehicles recharge in metropolitan area," in *Electrical Power Quality and Utilisation (EPQU), 2011 11th International Conference on*, 2011, pp. 1-6.
- [4] N. Rotering and M. Ilic, "Optimal Charge Control of Plug-In Hybrid Electric Vehicles in Deregulated Electricity Markets," *Power Systems, IEEE Transactions on*, vol. 26, pp. 1021-1029, 2011.
- [5] S. Haghbin, S. Lundmark, M. Alakula, and O. Carlson, "Grid-Connected Integrated Battery Chargers in Vehicle Applications: Review and New Solution," *Industrial Electronics, IEEE Transactions on*, vol. 60, pp. 459-473, 2013.
- [6] E. Sortomme, M. M. Hindi, S. D. J. MacPherson, and S. S. Venkata, "Coordinated Charging of Plug-In Hybrid Electric Vehicles to Minimize Distribution System Losses," *Smart Grid, IEEE Transactions on*, vol. 2, pp. 198-205, 2011.
- [7] C. Pang, P. Dutta, and M. Kezunovic, "BEVs/PHEVs as Dispersed Energy Storage for V2B Uses in the Smart Grid," *Smart Grid, IEEE Transactions on*, vol. 3, pp. 473-482, 2012.
- [8] Z. Darabi and M. Ferdowsi, "Aggregated Impact of Plug-in Hybrid Electric Vehicles on Electricity Demand Profile," *Sustainable Energy, IEEE Transactions on*, vol. 2, pp. 501-508, 2011.
- [9] J. Taylor, A. Maitra, M. Alexander, D. Brooks, and M. Duvall, "Evaluation of the impact of plug-in electric vehicle loading on distribution system operations," in *Power & Energy Society General Meeting, 2009. PES '09. IEEE*, 2009, pp. 1-6.
- [10] J. T. Salihi, "1974 Energy Requirements for Electric Cars and Their Impact on Electric Power Generation and Distribution Systems," *Industry Applications, IEEE Transactions on*, vol. IA-20, pp. 1095-1095, 1984.

- [11] "J1772TM, new fast-charging "Combo Coupler" standard for PHEVs and EVs," *Ground Vehicle Standards Newsletter*., vol. 3, pp. 1-2, November 2012.
- [12] M. Kinter-Meyer, K. Schneider, and R. Pratt, "Impacts Assessment of Plug-In Hybrid Electric Vehicles on Electric Utilities and Regional U.S. Power Grids, Part 1: Technical Analysis," *Pacific Northwest National Laboratory, Richland, WA, 2007.*, 2007.
- [13] Electric Power Research Institute, "Environmental Assessment of Plug-In Hybrid Electric Vehicles," July 2007.
- [14] Deborah gordon, Daniel sperling, and D. livingston, "Policy Priorities for Advancing the U.S. Electric Vehicle Market," September 2012.
- [15] K. Clement-Nyns, E. Haesen, and J. Driesen, "The Impact of Charging Plug-In Hybrid Electric Vehicles on a Residential Distribution Grid," *Power Systems, IEEE Transactions on*, vol. 25, pp. 371-380, 2010.
- [16] C. Farmer, P. Hines, J. Dowds, and S. Blumsack, "Modeling the Impact of Increasing PHEV Loads on the Distribution Infrastructure," in *System Sciences (HICSS), 2010 43rd Hawaii International Conference on*, 2010, pp. 1-10.
- [17] F. Geth, N. Leemput, V. J. Roy, J. Büsche, R. Ponnette, and J. Driesen, "Voltage Droop Charging of Electric Vehicles in a Residential Distribution Feeder," presented at the IEEE PES ISGT Europe, Berlin, Germany, 2012.
- [18] KEMA, Inc, and ISO/RTO Council, "Assessment of Plug-in Electric Vehicle Integration with ISO/RTO Systems," March 2010.
- [19] A. K. Srivastava, B. Annabathina, and S. Kamalasadan, "The Challenges and Policy Options for Integrating Plug-in Hybrid Electric Vehicle into the Electric Grid," *Electricity Journal*, vol. 23, pp. 83-91, April 2010 2010.
- [20] T. H. Bradley and A. A. Frank, "Design, demonstrations and sustainability impact assessments for plug-in hybrid electric vehicles," *Renewable & Sustainable Energy Reviews*, vol. 13, pp. 115-128, Jan 2009.
- [21] S. S. Williamson, "Electric Drive Train Efficiency Analysis Based on Varied Energy Storage System Usage for Plug-In Hybrid Electric Vehicle Applications," in *Power Electronics Specialists Conference, 2007. PESC 2007. IEEE*, 2007, pp. 1515-1520.
- [22] P. Denholm and W. Short, "An Evaluation of Utility System Impacts and Benefits of Optimally Dispatched Plug-In Hybrid Electric Vehicles," *National Renewable Energy Laboratory, Tech. Rep.*, October 2006.
- [23] Z. Menyang, Y. Yan, and C. C. Mi, "Analytical Approach for the Power Management of Blended-Mode Plug-In Hybrid Electric Vehicles," *Vehicular Technology, IEEE Transactions on*, vol. 61, pp. 1554-1566, 2012.

- [24] B. Sanzhong, Y. Du, and S. Lukic, "Optimum design of an EV/PHEV charging station with DC bus and storage system," in *Energy Conversion Congress and Exposition (ECCE), 2010 IEEE*, 2010, pp. 1178-1184.
- [25] M. Yilmaz and P. T. Krein, "Review of Battery Charger Topologies, Charging Power Levels, and Infrastructure for Plug-In Electric and Hybrid Vehicles," *Power Electronics, IEEE Transactions on*, vol. 28, pp. 2151-2169, 2013.
- [26] P. E. Mike Waters, "Plug-in Vehicles & the Grid," in *NC Sustainable Energy Conference*, April 26 th, 2011.
- [27] M. Etezadi-Amoli, K. Choma, and J. Stefani, "Rapid-Charge Electric-Vehicle Stations," *Power Delivery, IEEE Transactions on*, vol. 25, pp. 1883-1887, 2010.
- [28] Jack Pokrzywa. (August 2011), "SAE's J1772 'combo connector' for ac and dc charging advances with IEEE's help". Available: <http://ev.sae.org/article/10128/>
- [29] L. L. Grigsby, *Electric Power Generation, Transmission, and Distribution*: CRC Press, May 2007.
- [30] W. Kempton and J. Tomic, "Vehicle-to-grid power fundamentals: Calculating capacity and net revenue," *Journal of Power Sources*, vol. 144, pp. 268-279, Jun 2005.
- [31] S. Hadley, "Potential impacts of plug-in hybrid electric vehicles on regional power generation," in *Oak Ridge National Laboratory, U.S. Department of Energy, Tech. Rep*, ed, 2008.
- [32] S. Blumsack, C. Samaras, and P. Hines, "Long-term electric system investments to support Plug-in Hybrid Electric Vehicles," in *Power and Energy Society General Meeting - Conversion and Delivery of Electrical Energy in the 21st Century, 2008 IEEE*, 2008, pp. 1-6.
- [33] C. Camus, C. M. Silva, T. L. Farias, and J. Esteves, "Impact of Plug-in Hybrid Electric Vehicles in the Portuguese electric utility system," in *Power Engineering, Energy and Electrical Drives, 2009. POWERENG '09. International Conference on*, 2009, pp. 285-290.
- [34] A. Maitra, J. Taylor, D. Brooks, M. Alexander, and M. Duvall, "Integrating plug-in-electric vehicles with the distribution system," in *Electricity Distribution - Part 1, 2009. CIRED 2009. 20th International Conference and Exhibition on*, 2009, pp. 1-5.
- [35] Ahmed Eltom and Mohammed A. Aziz, "The economics of energy efficient motors during unbalanced voltage conditions," in *Power Engineering Society Inaugural Conference and Exposition in Africa, 2005 IEEE*, 2005, pp. 378-384.

- [36] Nader S. Moharari, "Microprocessor Based Protection Of Induction Motors, Using Thermal, Mechanical, And Skin Effect Electrical Models to Predict Motor Temperature Rise," Master of Science in Engineering, Electrical Engineering, The University of Tennessee , Chattanooga, 1989.
- [37] Available:
http://www.mathworks.com/help/releases/R13sp2/pdf_doc/physmod/powersys/power_conversion.pdf.
- [38] U. A. Khan, J. K. Seong, S. H. Lee, S. H. Lim, and B. W. Lee, "Feasibility Analysis of the Positioning of Superconducting Fault Current Limiters for the Smart Grid Application Using Simulink and SimPowerSystem," *Applied Superconductivity, IEEE Transactions on*, vol. 21, pp. 2165-2169, 2011.
- [39] M. Manyase and P. Pillay, "Power Engineering Review, IEEE " vol. 22, pp. 49-50, 2002.
- [40] K. Lee, G. Venkataramanan, and T. M. Jahns, "Modeling Effects of Voltage Unbalances in Industrial Distribution Systems With Adjustable-Speed Drives," *Industry Applications, IEEE Transactions on*, vol. 44, pp. 1322-1332, 2008.

APPENDIX A
DISTRIBUTION SYSTEM FOR VOLTAGE STUDY

Real power demand of all service transformers

Transformer Labeling	Transformer KVA Rating	No. of customers connected	Peak demand (2.30PM)	Off-Peak demand (6.30AM)
			Real Power (KW)	Real Power (KW)
OW5006	50	1	1.094	0.986
OW51142	25	2	8.800	8.112
OW51325	15	1	0.252	0.288
OW5562	37	8	6.412	9.940
OW5567	37	1	0.652	2.448
OW5568	25	2	1.072	0.980
OW5656	25	4	7.536	1.760
OW5657	25	1	0.180	5.508
OW5658	25	7	3.088	13.328
OW5666	37	9	13.068	4.488
OW5739	37	2	1.472	2.192
OW5741	37	3	4.236	3.916
OW5800	15	1	0.272	0.032
OW5880	37	2	0.268	1.016
OW5882	25	1	3.484	0.700
OW5883	25	2	1.348	2.848
OW5884	37	1	0.448	0.392
OW5913	25	1	3.244	0.448
OW5915	50	2	1.116	1.096
OW5917	37	2	3.592	2.804
OW5925	37	2	3.100	5.876
OW5P024	37	1	6.404	0.248
OW5P025	37	3	5.404	6.540
OW5P026	50	3	5.072	7.588
OW5P109	100	18	24.888	19.348
OW5P110	100	18	22.152	21.960
OW5P111	100	18	15.412	19.988
OW5P112	100	18	12.556	25.560
OW5P232	500	1	0.264	0.128
OW5932	50	2	1.116	1.096
OW5502	50	3	1.094	0.986
OW51593	50	2	1.116	1.096
OW5566	15	1	0.272	0.032
OW5557	25	4	8.800	8.112
OW5558	25	1	1.072	0.980
OW5P018	75	1	1.304	4.896
OW5683	37	1	6.412	9.940
OW5835	37	9	0.652	2.448
OW5838	37	3	13.068	4.488
OW51657	25	7	7.536	1.760
OW5839	50	3	5.072	7.588
OW5840	25	2	0.180	5.508
OW5P165	225	1	0.325	0.156
OW5P244	75	2	0.756	1.620

APPENDIX B
INTELLIRUPTERS DATA

Voltages and currents at peak and off-peak demand on 01/10/2013 for A55661

Intellirupters	Power Demand			X-side	Y-side
A55661	Peak	Phase Voltages (KV)	VA	7.143	7.141
			VB	7.102	7.115
			VC	7.097	7.094
		Phase Currents(A)	IA	197	
			IB	195	
			IC	186	
	Off-Peak	Phase Voltages (KV)	VA	7.122	7.120
			VB	7.087	7.100
			VC	7.072	7.069
		Phase Currents(A)	IA	135	
			IB	131	
			IC	123	

Voltages and currents at peak and off-peak demand on 01/10/2013 for A55661

Intellirupters	Power Demand			X-side	Y-side
B51432	Peak	Phase Voltages (KV)	VA	7.125	7.122
			VB	7.091	7.095
			VC	7.088	7.090
		Phase Currents(A)	IA	58	
			IB	79	
			IC	52	
	Off-Peak	Phase Voltages (KV)	VA	7.108	7.106
			VB	7.082	7.086
			VC	7.065	7.068
		Phase Currents(A)	IA	48	
			IB	62	
			IC	43	

VITA

Sharmila Kumari Bunga was born in Sompeta, India. She completed her Bachelor of Engineering degree in Electrical and Electronics Engineering from Andhra University, India, and she has also received her Master of Technology degree in Electrical Power Engineering from Jawaharlal Nehru Technological University, Hyderabad, India. Sharmila started the Masters in Electrical Engineering in University of Tennessee at Chattanooga in Fall 2010. Simultaneously, she worked as a graduate assistant for electrical engineering department up till December 2012. Sharmila graduated with a Master of Science degree in Electrical Engineering in May 2013.